

Map ID
Direction
Distance
Elevation

MAP FINDINGS

EDR ID Number
EPA ID Number

KJ1430
ENE
> 1
1.804 mi.
9523 ft.

RECLOSURE SWITCH LEAK AT POLE 37281
EAST 21 STREET & AVENUE X
BROOKLYN, NY

NY Spills S109062583
N/A

Site 1 of 2 in cluster KJ

Relative:
Higher

Actual:
14 ft.

SPILLS:

Name: RECLOSURE SWITCH LEAK AT POLE 37281
Address: EAST 21 STREET & AVENUE X
City,State,Zip: BROOKLYN, NY
Spill Number/Closed Date: 0801453 / 2008-05-19
Facility ID: 0801453
Facility Type: ER
DER Facility ID: 346800
Site ID: 397375
DEC Region: 2
Spill Cause: Equipment Failure
Spill Class: C4
SWIS: 2401
Spill Date: 2008-05-06
Investigator: gdbreen

Referred To: Not reported
Reported to Dept: 2008-05-06
CID: 78
Water Affected: Not reported
Spill Source: Unknown
Spill Notifier: Other
Cleanup Ceased: Not reported
Cleanup Meets Std: False
Last Inspection: Not reported
Recommended Penalty: False
UST Trust: Not reported
Remediation Phase: 0
Date Entered In Computer: 2008-05-07
Spill Record Last Update: 2008-05-19
Spiller Name: ERT
Spiller Company: CON EDISON
Spiller Address: EAST 21ST / AVE X
Spiller Company: 999
Contact Name: ERT
DEC Memo: "05/19/08 - See eDocs for Con Ed report detailing cleanup and closure. 211229. see eDocs"

Remarks: "1/2 pint spilled onto the ground from pole. A reclosure failed. No to the 5 questions. Spill is not yet cleaned, but a crew is enroute to evaluate. Con Ed Referenced No. is 211229."

All Materials:

Site ID: 397375
Operable Unit ID: 1154343
Operable Unit: 01
Material ID: 2145136
Material Code: 0541A
Material Name: dielectric fluid
Case No.: Not reported
Material FA: Petroleum
Quantity: Not reported
Units: G
Recovered: .00
Oxygenate: Not reported